



## Legislation Details (With Text)

---

**File #:** 44491      **Version:** 1      **Name:** 3418 S STONE CREEK CIR  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 9/16/2016      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 9/20/2016  
**Enactment date:**      **Enactment #:**

**Title:** 3418 S Stone Creek Cir (C-09-59-2016)  
Bouril Design appealing IBC 1208.2.1. The ruling requires the furred ceiling high to be 7'0". In addition the minimum door height shall be 80". The variance requested is to have a ceiling height in the basement of 6'7" and door heights of 76.5". The Madison Fire Department supports the variance with an extended smoke alarm system and a sprinkler system.

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 3418 S STONE CREEK CIR.pdf

Date	Ver.	Action By	Action	Result
9/20/2016	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

### **Title**

3418 S Stone Creek Cir (C-09-59-2016)  
Bouril Design appealing IBC 1208.2.1. The ruling requires the furred ceiling high to be 7'0". In addition the minimum door height shall be 80". The variance requested is to have a ceiling height in the basement of 6'7" and door heights of 76.5". The Madison Fire Department supports the variance with an extended smoke alarm system and a sprinkler system.