



Legislation Details (With Text)

File #: 44082 **Version:** 1 **Name:** 7838 Courtyard Dr
Type: Miscellaneous **Status:** Approved
File created: 8/11/2016 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 8/16/2016
Enactment date: **Enactment #:**
Title: 7838 Courtyard Dr (C-08-55-2016)

Rodney Helt, AIA appealing IBC 1208.2.1. The rule requires ceilings to be 7'0". The variance requested is to allow existing ceiling height of 6'6". The proposal is to finish an existing basement in a condo unit.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 7838 Courtyard Dr.pdf

Date	Ver.	Action By	Action	Result
8/16/2016	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

Title

7838 Courtyard Dr (C-08-55-2016)

Rodney Helt, AIA appealing IBC 1208.2.1. The rule requires ceilings to be 7'0". The variance requested is to allow existing ceiling height of 6'6". The proposal is to finish an existing basement in a condo unit.