



Legislation Details (With Text)

File #: 34447 **Version:** 1 **Name:** 829 E. Washington Avenue
Type: Miscellaneous **Status:** Approved
File created: 6/10/2014 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 6/17/2014
Enactment date: **Enactment #:**
Title: 829 E. Washington Avenue (C-06-37-2014)
Tills Architecture appealing IBC 1009.7, Vertical Rise. The rule limits a flight of stairs to 12' 0". The Variance requested is to allow a rebuilt stairway to be 12' 9". The Madison Fire Department supports the Variance.
Sponsors:
Indexes:
Code sections:
Attachments: 1. 829 E Washington Ave.pdf

Date	Ver.	Action By	Action	Result
6/17/2014	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass

Title

829 E. Washington Avenue (C-06-37-2014)
Tills Architecture appealing IBC 1009.7, Vertical Rise. The rule limits a flight of stairs to 12' 0". The Variance requested is to allow a rebuilt stairway to be 12' 9". The Madison Fire Department supports the Variance.