



## Legislation Details (With Text)

---

**File #:** 44083      **Version:** 1      **Name:** 3425 Hargrove St  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 8/11/2016      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 8/16/2016  
**Enactment date:**      **Enactment #:**  
**Title:** 3425 Hargrove St (M-08-56-2016)

Ed Wimmer (builder) appealing SPS 321.08. The rule requires a fire rating when a detached building is less than 10 feet away. They want to use a non rated door.

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 3425 Hargrove St.pdf

| Date      | Ver. | Action By   | Action  | Result |
|-----------|------|---|---------|--------|
| 8/16/2016 | 1    | BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD | Approve |        |

**Title**

3425 Hargrove St (M-08-56-2016)

Ed Wimmer (builder) appealing SPS 321.08. The rule requires a fire rating when a detached building is less than 10 feet away. They want to use a non rated door.