



Legislation Details (With Text)

File #: 43280 **Version:** 1 **Name:** 810 East Washington
Type: Miscellaneous **Status:** Approved
File created: 6/2/2016 **In control:** BOARD OF REVIEW
On agenda: **Final action:** 6/7/2016
Enactment date: **Enactment #:**

Title: 810 East Washington (C-06-33-2016)
Christopher Gosch of Bark Design appealing IBC section 3007.1. The rule requires that a fire service elevator serve all levels in a structure. The variance requested is to allow the elevator to serve the floor below the highest floor. Additional means of safety have been provided. The variance is supported by the Madison Fire Department.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 810 EAST WASHINGTON.pdf

Date	Ver.	Action By	Action	Result
6/7/2016	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

Title

810 East Washington (C-06-33-2016)
Christopher Gosch of Bark Design appealing IBC section 3007.1. The rule requires that a fire service elevator serve all levels in a structure. The variance requested is to allow the elevator to serve the floor below the highest floor. Additional means of safety have been provided. The variance is supported by the Madison Fire Department.