



## Legislation Details (With Text)

**File #:** 43270      **Version:** 1      **Name:** 433 W Johnson  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 6/2/2016      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 6/7/2016  
**Enactment date:**      **Enactment #:**

**Title:** 433 W Johnson (C-06-34-2016)  
John Sutton of Sutton Architecture appealing IBC 3007.4. The proposal is to use the 2015 IBC. The existing elevators are not fire service elevators. The two elevators will be converted to fire service elevators and lobbies created. The mechanical parking ramp below grade will be served by a pressurized stairwell. The Madison Fire Department supports the variance with the following conditions:  
-Construct 160-square foot elevator lobbies.  
-Install 45-minute rated doors for all doors opening into corridors as permitted in the 2015 edition of the IBC.  
-Add stair pressurization to Stair C.  
-Meet all other requirements of IBC 3007, hoistway lighting, electrical power, and protection of wiring & cables.  
-Construct elevator lobbies on each floor that comply with the required fire openings.  
-Update plans in the Fire Command Center.  
-Update the smoke control panel to include the stair pressurization for Stair C.

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 433 W JOHNSON.pdf

Date	Ver.	Action By	Action	Result
6/7/2016	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

**Title**

433 W Johnson (C-06-34-2016)  
John Sutton of Sutton Architecture appealing IBC 3007.4. The proposal is to use the 2015 IBC. The existing elevators are not fire service elevators. The two elevators will be converted to fire service elevators and lobbies created. The mechanical parking ramp below grade will be served by a pressurized stairwell. The Madison Fire Department supports the variance with the following conditions:  
-Construct 160-square foot elevator lobbies.  
-Install 45-minute rated doors for all doors opening into corridors as permitted in the 2015 edition of the IBC.  
-Add stair pressurization to Stair C.  
-Meet all other requirements of IBC 3007, hoistway lighting, electrical power, and protection of wiring & cables.  
-Construct elevator lobbies on each floor that comply with the required fire openings.  
-Update plans in the Fire Command Center.  
-Update the smoke control panel to include the stair pressurization for Stair C.