



Legislation Details (With Text)

**File #:** 69265      **Version:** 1      **Name:**  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 1/11/2022      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 1/18/2022  
**Enactment date:**      **Enactment #:**

**Title:** 702 Pflaum Rd  
BLDVAR-2021-19924  
2015 IBC 903.1.1 - The applicant is seeking an exemption from the requirement that an automatic sprinkler system be installed throughout the space. Specifically the applicant is seeking to forgo installing an automatic sprinkler system over the pool area within the building.  
Alder District 15.

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 2021\_1216 MMSD LaFollette Signed Variance Application.pdf, 2. Pflaum Rd 702 IBC 903 MFD Position 1-11-2022.pdf

Date	Ver.	Action By	Action	Result
1/18/2022	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

**Title**

702 Pflaum Rd  
BLDVAR-2021-19924  
2015 IBC 903.1.1 - The applicant is seeking an exemption from the requirement that an automatic sprinkler system be installed throughout the space. Specifically the applicant is seeking to forgo installing an automatic sprinkler system over the pool area within the building.  
Alder District 15.