



## Legislation Details (With Text)

---

**File #:** 37296      **Version:** 1      **Name:** 18 N Carroll St  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 2/12/2015      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 2/17/2015  
**Enactment date:**      **Enactment #:**  
**Title:** 18 N. Carroll Street (C-02-12-2015)  
Kontext Architects appealing IBC 1027.1. The variance requested is to allow an existing horizontal exit to remain for a new restaurant. The Madison Fire Department supports the Variance with additional means of safety.  
**Sponsors:**  
**Indexes:**  
**Code sections:**  
**Attachments:** 1. 18 N Carroll St.pdf

Date	Ver.	Action By	Action	Result
2/17/2015	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass

**Title**  
18 N. Carroll Street (C-02-12-2015)  
Kontext Architects appealing IBC 1027.1. The variance requested is to allow an existing horizontal exit to remain for a new restaurant. The Madison Fire Department supports the Variance with additional means of safety.