



Legislation Details (With Text)

File #:	54746	Version:	1	Name:	308 S Paterson St
Type:	Miscellaneous	Status:	Approved		
File created:	2/15/2019	In control:	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD		
On agenda:		Final action:	2/20/2019		
Enactment date:		Enactment #:			
Title:	308 S. Paterson St BLDNCC-2018-02241 James McFadden is seeking a variance to allow the ceiling height in the basement to remain 6' with 5' 5.5" clearance under the beams. IBC 1003.2 requires 7' 6" minimum ceiling height. The space is not normally occupied and will have a cooler and some storage. The Madison Fire Department has conditionally approved the variance. Alder District 6				
Sponsors:					
Indexes:					
Code sections:					
Attachments:	1. 308_S_Paterson.pdf				

Date	Ver.	Action By	Action	Result
2/20/2019	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

Title

308 S. Paterson St
BLDNCC-2018-02241

James McFadden is seeking a variance to allow the ceiling height in the basement to remain 6' with 5' 5.5" clearance under the beams. IBC 1003.2 requires 7' 6" minimum ceiling height. The space is not normally occupied and will have a cooler and some storage. The Madison Fire Department has conditionally approved the variance. Alder District 6