



Legislation Details (With Text)

**File #:** 47296      **Version:** 1      **Name:** 432 W GORHAM ST  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 5/11/2017      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 5/16/2017  
**Enactment date:**      **Enactment #:**

**Title:** 432 W Gorham St (C-05-29-2017)  
 Antunovich Associates appealing IBC 3007.4.4. The rule requires that the Fire Service Access Elevator Lobby be a minimum of 150 sq. ft. in area with a minimum dimension of 8'. The variance requested is to allow a lobby of 184 sq. ft. with dimensions of 7'2" x 25'9". The Madison Fire Department recommends approval. Aldermanic District 4

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 432 W GORHAM ST.pdf

Date	Ver.	Action By	Action	Result
5/16/2017	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	

**Title**

432 W Gorham St (C-05-29-2017)  
 Antunovich Associates appealing IBC 3007.4.4. The rule requires that the Fire Service Access Elevator Lobby be a minimum of 150 sq. ft. in area with a minimum dimension of 8'. The variance requested is to allow a lobby of 184 sq. ft. with dimensions of 7'2" x 25'9". The Madison Fire Department recommends approval. Aldermanic District 4