



City of Madison

City of Madison
Madison, WI 53703
www.cityofmadison.com

Legislation Text

File #: 46071, **Version:** 1

Title

4802 Femrite Dr (C-02-05-2017)

JSD Inc appealing IBC 1008.1.7. Threshold shall be less than 3/4 of an inch. The variance requested is to have a threshold of six inches in a cooler addition. The Madison Fire Department supports the variance with a contrasting color on the threshold. 16th Ald. Dist.