



City of Madison

City of Madison
Madison, WI 53703
www.cityofmadison.com

Legislation Text

File #: 44081, **Version:** 1

Title

506 State St (C-08-54-2016)

Agent: L2M Inc, appealing IBC 2009 1009.2 headroom, 1009.4.2 stair risers, and 1009.4.2 minimum stair treads. The variance requested is to allow 5' 10" headroom, 8 inch risers, and 10 inch treads for an existing condition.