



# City of Madison

City of Madison  
Madison, WI 53703  
[www.cityofmadison.com](http://www.cityofmadison.com)

## Legislation Text

---

**File #:** 44080, **Version:** 1

---

### **Title**

22 S Carroll St (C-08-53-2016)

Destree Design appealing IBC 1009.5 stairways and landings. The rule requires that a landing be provided at a door. The variance requested is to waive the landing for an existing condition. A gate will be provided at the base of the stairway to reduce the vagrancy issue. The Madison Fire Department supports the installation of the gate.