



## Legislation Details

---

**File #:** 44080      **Version:** 1      **Name:** 22 S Carroll St  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 8/11/2016      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 8/16/2016  
**Enactment date:**      **Enactment #:**  
**Title:** 22 S Carroll St (C-08-53-2016)

Destree Design appealing IBC 1009.5 stairways and landings. The rule requires that a landing be provided at a door. The variance requested is to waive the landing for an existing condition. A gate will be provided at the base of the stairway to reduce the vagrancy issue. The Madison Fire Department supports the installation of the gate.

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 22 S Carroll St.pdf

Date	Ver.	Action By	Action	Result
8/16/2016	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	