



Legislation Details

File #: 38045 **Version:** 1 **Name:** 9414 Silicon Prairie Parkway
Type: Miscellaneous **Status:** Approved
File created: 4/15/2015 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 4/21/2015
Enactment date: **Enactment #:**
Title: 9414 Silicon Prairie Parkway (C-04-22-2015)
Kevin Burow of Knothe & Bruce Architects appealing IBC 1009.4.2, Riser Height. The Code allows stairways within the unit to be 7 3/4". The Variance requested is to allow poured in place concrete stairs to remain that have a rise of 7 1/4", that are exterior to the unit.
Sponsors:
Indexes:
Code sections:
Attachments: 1. 9414 Silicon Prairie Pkwy.pdf

Date	Ver.	Action By	Action	Result
4/21/2015	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass