



Legislation Details

File #: 42502 **Version:** 1 **Name:** 115 State St
Type: Miscellaneous **Status:** Approved
File created: 4/13/2016 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 4/19/2016
Enactment date: **Enactment #:**
Title: 115 State Street (M-04-20-2016)

Bill Montelbano appealing MGO 29.37(2)(b). The rule requires that all buildings and additions in the Capital Fire District be non-combustible construction. The variance requested is to allow some wood construction. Additional means of safety is being provided by sprinklering the second floor. In addition, sprinkler outlets shall be provided to sprinkler the first floor. The Madison Fire Department supports the variance with sprinklers as noted above.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 115 State St.pdf

Date	Ver.	Action By	Action	Result
4/19/2016	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	