



Legislation Text

File #: 35197, **Version:** 1

Title

3846 Maple Grove Drive (C-08-44-2014)

Greg Held of Knothe & Bruce Architects, LLC appealing IBC 2009 1104.1 Site Arrival Points: Accessible routes within the site shall be provided from public transportation stops; accessible parking; accessible passenger loading zones; and public streets or sidewalks to the accessible building entrance served. There are no surface parking stalls on the lot for this building. There is parking within the basement, including two accessible car stalls, but there is not sufficient headroom in the basement to provide an accessible van stall. Accessible parking will be provided via an easement adjacent to the building.