



# City of Madison

City of Madison  
Madison, WI 53703  
www.cityofmadison.com

## Legislation Text

---

**File #:** 54643, **Version:** 1

---

### **Title**

4101 Lien Rd.

BLDNCC-2018-14504

Roger Schregardus of Boldt Technical Services is seeking a variance to allow a 12" landing instead of the 44" landing as required under IBC 1010.1.6. The doors in question are Fire Department Access doors to high-piled storage per IFC 3206.6.1. The Fire Department Supports the variance.

Alder District 17