



# City of Madison

City of Madison  
Madison, WI 53703  
www.cityofmadison.com

## Legislation Text

---

**File #:** 50542, **Version:** 1

---

### **Title**

604 Roger St (M-02-12-2018)

Erin & Graham Jonaitis, appealing the SPS 321.04(2)(d) Stair Headroom and SPS 321.06 Headroom in basement.

The variance was processed on precedence. The standard equivalency is an interconnected hardwired smoke detector between the basement and first floor. The appellant does not want to provide that.

Alder District 6