



## Legislation Text

---

**File #:** 36882, **Version:** 1

---

### **Title**

316 W. Washington Avenue (C-01-01-15)

Ray White of Dimension IV Madison, LLC appealing IBC 1023.5. The rule does not allow elevators to open into an exit passageway. The Variance is to allow an additional elevator shaft door in Stair 8. The Madison Fire Department supports the Variance with the additional means of safety provided.