



City of Madison

City of Madison
Madison, WI 53703
www.cityofmadison.com

Legislation Text

File #: 40456, **Version:** 1

Title

109 E. Lakeside Street (C-10-50-2015)

Charlie Ethridge of Glueck Architects appeals IBC 705.8. The rule requires that from 0 to 3 feet openings are not permitted. This is an existing building that is undergoing a change of use. There is a permanent utility easement along the wall in question so it cannot be built upon. The Madison Fire Department supports the variance.