



City of Madison

City of Madison
Madison, WI 53703
www.cityofmadison.com

Legislation Text

File #: 44082, **Version:** 1

Title

7838 Courtyard Dr (C-08-55-2016)

Rodney Helt, AIA appealing IBC 1208.2.1. The rule requires ceilings to be 7'0". The variance requested is to allow existing ceiling height of 6'6". The proposal is to finish an existing basement in a condo unit.