



Legislation Details

File #: 41765 **Version:** 1 **Name:** 636 State Street
Type: Miscellaneous **Status:** Approved
File created: 2/10/2016 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 2/23/2016
Enactment date: **Enactment #:**

Title: 636 State Street (C-02-09-2016)
Jenny Dechant of Iconica appealing IBC 705.8.1. The rule does not allow openings on a property line. The variance requested is to allow an existing stairway at 610 State Street to lead to the basement at 638 State Street. A new two hour enclosure would be constructed. The Madison Fire Department supports the variance with conditions.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 636 State Street.pdf

Date	Ver.	Action By	Action	Result
2/23/2016	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	