



Legislation Details

File #: 37286 **Version:** 1 **Name:** 822 E Washington Ave
Type: Miscellaneous **Status:** Approved
File created: 2/12/2015 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 2/17/2015
Enactment date: **Enactment #:**

Title: 822 E. Washington Avenue (C-02-10-2015)
Christopher Gosch of Bark Design appealing Section 503.1 of the 2009 IBC. The lowest level below the tower is IIB. The proposal is to separate the IIB from IA with a three hour horizontal fire separation. Three hour vertical fire walls will be used to separate the vertical areas. The Madison Fire Department supports the Variance.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 822 E Washington Ave.pdf

Date	Ver.	Action By	Action	Result
2/17/2015	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass