



Legislation Text

File #: 37286, **Version:** 1

Title

822 E. Washington Avenue (C-02-10-2015)

Christopher Gosch of Bark Design appealing Section 503.1 of the 2009 IBC. The lowest level below the tower is IIB. The proposal is to separate the IIB from IA with a three hour horizontal fire separation. Three hour vertical fire walls will be used to separate the vertical areas. The Madison Fire Department supports the Variance.