



## Legislation Text

---

**File #:** 37286, **Version:** 1

---

### **Title**

822 E. Washington Avenue (C-02-10-2015)

Christopher Gosch of Bark Design appealing Section 503.1 of the 2009 IBC. The lowest level below the tower is IIB. The proposal is to separate the IIB from IA with a three hour horizontal fire separation. Three hour vertical fire walls will be used to separate the vertical areas. The Madison Fire Department supports the Variance.