



# City of Madison

City of Madison  
Madison, WI 53703  
www.cityofmadison.com

## Legislation Text

---

**File #:** 43738, **Version:** 1

---

### **Title**

9614 Red Forest Lane (M-07-45-2016)

TR McKenzie appealing IBC 3004.1, 2009. The rule requires that hoistway venting be required for shafts of 3 or more stories. The variance requested is to use the 2015 IBC that does not require the venting. The Madison Fire Department supports the variance.