



City of Madison

City of Madison
Madison, WI 53703
www.cityofmadison.com

Legislation Text

File #: 45475, **Version:** 1

Title

4310 Mohawk Dr (C-12-75-2016)

Conor Nelan of Cold Spring Design appealing IBC 1208.2. The rule requires clearance at obstructions to be 7' 6". The variance requested is to allow a beam 7' 0" and one at 7' 3". The Madison Fire Department recommends conditional approval. 10th Ald. Dist.