



## Legislation Details

---

**File #:** 43755      **Version:** 1      **Name:** 2505-2525 University Ave  
**Type:** Miscellaneous      **Status:** Approved  
**File created:** 7/13/2016      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 7/19/2016  
**Enactment date:**      **Enactment #:**  
**Title:** 2505-2525 University Ave (C-07-46-2016)

Brenda McClure of Gary Brink & Associates, Inc. appealing IBC 1104.2. The rule requires the building at 2505 have an accessible parking stall. The variance requested is to allow the stall at 2525 University to be the accessible stall. The existing shared parking easement to include the accessible stall and access aisle.

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 2505-2525 University Ave.pdf

Date	Ver.	Action By	Action	Result
7/19/2016	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	