



Legislation Details

File #: 69266 **Version:** 1 **Name:**
Type: Miscellaneous **Status:** Approved
File created: 1/11/2022 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 1/18/2022
Enactment date: **Enactment #:**

Title: 201 S Gammon
BLDVAR-2021-19925
2015 IBC 903.1.1 - The applicant is seeking an exemption from the requirement that an automatic sprinkler system be installed throughout the space. Specifically the applicant is seeking to forgo installing an automatic sprinkler system over the pool area within the building.
Alder District 19.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 2021_1216 MMSD Memorial HS Signed Variance Application.pdf, 2. Gammon Rd 201 S IBC 903 MFD Position 1-11-2022.pdf

Date	Ver.	Action By	Action	Result
1/18/2022	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	