



Legislation Details

---

**File #:** 55337      **Version:** 1      **Name:** 1000 Edgewood College Drive  
**Type:** Miscellaneous      **Status:** Held in Committee  
**File created:** 4/8/2019      **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE  
CODE AND LICENSING APPEALS BOARD  
**On agenda:**      **Final action:** 3/31/2022  
**Enactment date:**      **Enactment #:**

**Title:** 1000 Edgewood College Dr.  
BLDNCC-2013-06890  
Michael Guns of Edgewood College is seeking a variance to request a special locking system for after hours for safety issues, such as an active shooter, appealing IBC 1010.1.9, which requires all exit doors to open from the egress side at all times. The City of Madison Fire Department has conditionally approved the variance.  
Alder District #13

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 1000\_edgewood\_college\_dr\_bba.pdf

Date	Ver.	Action By	Action	Result
5/21/2019	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Table	