



Legislation Details

File #: 43740 **Version:** 1 **Name:** 9619 Ancient Oak Lane
Type: Miscellaneous **Status:** Approved
File created: 7/13/2016 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 7/19/2016
Enactment date: **Enactment #:**
Title: 9619 Ancient Oak Lane (C-07-46-2016)
TR McKenzie Inc appealing IBC 3004.1, 2009. The rule requires that hoistway venting be required for shafts of 3 or more stories. The variance requested is to use the 2015 IBC that does not require the venting. The Madison Fire Department supports the variance.
Sponsors:
Indexes:
Code sections:
Attachments: 1. 9619 Ancient Oak Lane.pdf

Date	Ver.	Action By	Action	Result
7/19/2016	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	