



Legislation Details

File #: 45475 **Version:** 1 **Name:** 4310 MOHAWK DR
Type: Miscellaneous **Status:** Approved
File created: 12/15/2016 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 12/20/2016
Enactment date: **Enactment #:**
Title: 4310 Mohawk Dr (C-12-75-2016)
Conor Nelan of Cold Spring Design appealing IBC 1208.2. The rule requires clearance at obstructions to be 7' 6". The variance requested is to allow a beam 7' 0" and one at 7' 3". The Madison Fire Department recommends conditional approval. 10th Ald. Dist.
Sponsors:
Indexes:
Code sections:
Attachments: 1. 4310 MOHAWK DR.pdf

Date	Ver.	Action By	Action	Result
12/20/2016	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	