



Legislation Details

File #: 36883 **Version:** 1 **Name:** 800 N. Block East Washington Avenue
Type: Miscellaneous **Status:** Approved
File created: 1/15/2015 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 1/20/2015
Enactment date: **Enactment #:**

Title: 800 N. Block East Washington Avenue (M-01-02-2015)
Chris Gosch of Bark Design appealing IBC 602.2. The rule requires that Type 1 and Type 2 Construction have non-combustible elements as listed in Table 601. The Variance requested is to use 12 heavy timber columns in the low rise grocery store. The Madison Fire Department supports the Variance.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 800 N Block East Washington Ave.pdf, 2. WholeTrees Attachment 1-20-15.pdf

Date	Ver.	Action By	Action	Result
1/20/2015	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass