



## Legislation Text

---

**File #:** 20827, **Version:** 1

---

### **Title**

1216 Spring Street (M-12-68-2010)

Chris Gosch of Bark Design appealing IFC Section 9.14.3.1.2 of the 2009 IFC Edition. The rule requires that a minimum of two connections be provided on two different streets for a fire pump water supply. The Variance requested is to provide one 12 inch supply.