



Legislation Details

File #: 49842 **Version:** 1 **Name:** 111 S Livingston Ave
Type: Miscellaneous **Status:** Approved
File created: 12/13/2017 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 12/19/2017
Enactment date: **Enactment #:**

Title: 111 S Livingston St M-12-87-2017
Dan Windorski of GRAEF appealing MGO 34.503. The rule, thru the adoption of the IFC 2015, requires a street to be 26 feet wide. The variance requested is to allow an existing street of 22 feet wide. The Madison Fire Department supports the variance. Alder District 6

Sponsors:

Indexes:

Code sections:

Attachments: 1. Livingston St 111 S application.pdf

Date	Ver.	Action By	Action	Result
12/19/2017	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	