



City of Madison

City of Madison
Madison, WI 53703
www.cityofmadison.com

Legislation Text

File #: 58548, **Version:** 1

Title

9 Red Maple Trail
BLDVAR-2019-18752

The property owner is seeking a variance from 2015 IBC 1030 requiring a second exit for a finished room below grade within a commercial building. The property owner is seeking to finish the basement recreation room and is proposing installation of a 13D sprinkler system within the basement area as means of equivalence. The City of Madison Fire Department conditionally approves. Alder District #9