



City of Madison

City of Madison
Madison, WI 53703
www.cityofmadison.com

Legislation Text

File #: 35198, **Version:** 1

Title

601 North Street (C-08-45-2014)

Jane Capito appealing IBC Table 602. The rule requires that a wood structure be 10' from the property line. There are not any wood structures within 10' of the pergola. The Fire Department supports the Variance if the pergola is removed if a structure is built within 20' of the property line.