



Legislation Text

File #: 27640, **Version:** 1

Title

306 W. Main Street (C-09-45-2012)

Iconica appealing IBC 706.1, Party Walls. The rule requires a fire wall be constructed along the internal property line without openings. The Variance requested is to build a "L" shaped building across an internal property line. The equivalency offered is there is an eighteen inch concrete deck over the parking garage below and a fire wall will be constructed at the property line. The openings will be protected with fire doors/shutters. This projection is on one piece of land, built in four stages. The final stage is completely separated from the rest of the complex.