



Legislation Details

File #: 38043 **Version:** 1 **Name:** 673 State Street
Type: Miscellaneous **Status:** Approved
File created: 4/15/2015 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 4/21/2015
Enactment date: **Enactment #:**
Title: 673 State Street (C-04-20-2015)
Glueck Architects appealing IBC 1010.6.1. The rule requires that landings not slope more than 2%. The Variance requested is to allow an existing slope of five inches in four feet.
Sponsors:
Indexes:
Code sections:
Attachments: 1. 673 State St.pdf

Date	Ver.	Action By	Action	Result
4/21/2015	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass