



City of Madison

City of Madison
Madison, WI 53703
www.cityofmadison.com

Legislation Text

File #: 37296, **Version:** 1

Title

18 N. Carroll Street (C-02-12-2015)

Kontext Architects appealing IBC 1027.1. The variance requested is to allow an existing horizontal exit to remain for a new restaurant. The Madison Fire Department supports the Variance with additional means of safety.