



Legislation Text

File #: 43280, **Version:** 1

Title

810 East Washington (C-06-33-2016)

Christopher Gosch of Bark Design appealing IBC section 3007.1. The rule requires that a fire service elevator serve all levels in a structure. The variance requested is to allow the elevator to serve the floor below the highest floor. Additional means of safety have been provided. The variance is supported by the Madison Fire Department.