



Legislation Details

File #: 83957 **Version:** 1 **Name:** 4216 St Clair St
Type: Miscellaneous **Status:** Approved
File created: 6/14/2024 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 6/18/2024
Enactment date: **Enactment #:**

Title: 4216 St Clair St
 BLDVAR-2024-09168
 The applicant is seeking a variance from SPS 321.04(2)(d) requiring stairways shall be provided with a minimum headroom clearance of 76 inches measured vertically from a line parallel to the nosing of the treads to the ceiling, soffit or any overhead obstruction directly above that line. alder District 11

Sponsors:

Indexes:

Code sections:

Attachments: 1. 4216 Saint Clair Street Building Variance Application.pdf

Date	Ver.	Action By	Action	Result
6/18/2024	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	