



City of Madison

City of Madison
Madison, WI 53703
www.cityofmadison.com

Legislation Text

File #: 33481, **Version:** 1

Title

540 State Street (C-03-14-2014)

IEBC 912.2 requires sprinklers for this change of use in the second floor. The existing water service is 1 1/2" - 2" and is inadequate to sprinkle the second level. It will cost \$55,000 to put in a 4" main. The proposal is to sprinkle the dining areas and both stairwells. The Fire Department requires the system be monitored and a new 4" main be provided within 8 years.