



## Legislation Text

---

**File #:** 36883, **Version:** 1

---

### **Title**

800 N. Block East Washington Avenue (M-01-02-2015)

Chris Gosch of Bark Design appealing IBC 602.2. The rule requires that Type 1 and Type 2 Construction have non-combustible elements as listed in Table 601. The Variance requested is to use 12 heavy timber columns in the low rise grocery store. The Madison Fire Department supports the Variance.