



City of Madison

City of Madison
Madison, WI 53703
www.cityofmadison.com

Legislation Text

File #: 36883, **Version:** 1

Title

800 N. Block East Washington Avenue (M-01-02-2015)

Chris Gosch of Bark Design appealing IBC 602.2. The rule requires that Type 1 and Type 2 Construction have non-combustible elements as listed in Table 601. The Variance requested is to use 12 heavy timber columns in the low rise grocery store. The Madison Fire Department supports the Variance.