



Legislation Details

File #: 29081 **Version:** 1 **Name:** 20 W. Mifflin Street
Type: Miscellaneous **Status:** Approved
File created: 2/8/2013 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 2/20/2013
Enactment date: **Enactment #:**

Title: 20 W. Mifflin Street (C-02-02-2013)
Jeremy Cynkar of Destree Design Architects appealing IBC 705.8.1, Protected Openings in Exterior Walls. In addition, appealing IBC 1005.2, Doors. A fully opened door shall not reduce the egress width more than 7 inches. The Variance sought is to relocate an existing egress door to an exit stairway. In addition, the ADA lift has a door that swings into an exit corridor.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 20 W Mifflin St.pdf

Date	Ver.	Action By	Action	Result
2/20/2013	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass