



Legislation Details

File #: 30894 **Version:** 1 **Name:** 2560 University Avenue
Type: Miscellaneous **Status:** Approved
File created: 7/10/2013 **In control:** BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD
On agenda: **Final action:** 7/16/2013
Enactment date: **Enactment #:**
Title: 2560 University Avenue (C-07-50-2013)
Destree Design Architects appealing IBC 2902.2. The rule requires that separate toilet facilities be provided where there are 15 or more occupants. The Variance requested is to allow one toilet room for 20 occupants.
Sponsors:
Indexes:
Code sections:
Attachments: 1. 2560 University Ave.pdf

Date	Ver.	Action By	Action	Result
7/16/2013	1	BUILDING CODE, FIRE CODE, CONVEYANCE CODE AND LICENSING APPEALS BOARD	Approve	Pass