



City of Madison

City of Madison
Madison, WI 53703
www.cityofmadison.com

Legislation Text

File #: 52448, **Version:** 1

Title

215 Martin Luther King Jr. Blvd C-07-60-2018

Randall Jacobs of MEP Associates, LLC appealing IMC section 607.3.3.2.1. The rule requires that a smoke detector be installed within five feet of a damper. There are two different situations. The Madison Fire Department supports the variance for a distance greater than 5 feet.

Alder District 4