



# City of Madison

City of Madison  
Madison, WI 53703  
www.cityofmadison.com

## Legislation Text

---

**File #:** 47656, **Version:** 1

---

### **Title**

903 Delaplaine Ct (M-06-51-2017)

Knothe & Bruce Architects LLC appealing MGO 34.604.

The ordinance requires an on-site fuel source for Emergency Standby Power Systems. The variance requested is to use the natural gas pipeline. The Madison Fire Department supports the variance with a separate connection.